




Power is knowledge.™

B100 Installation Manual

LifeSafety Power®



FLEXPOWER®



LifeSafety Power | PH 888.577.2898 | TechSupport@LifeSafetyPower.com

Description

The B100 provides an additional voltage in a FlexPower system. This voltage can either be accessed directly via the B100's terminals or through other FlexPower Accessory Boards. The B100's input is typically supplied by the B1 buss in the system, allowing the main power supply's battery set to back up the B100's output voltage without the need for a second battery set. Output settings for the B100 include a fixed 12V setting and an adjustable setting of 5 to 18V. Multiple B100s can be added to a system for virtually unlimited voltage combinations.

Specifications

Input	Voltage	8-25V (Must be at least 3V above output voltage setting)
	Current	3.5A maximum
	Standby Current	35mA
Output	Voltage	4.7-23V
	Current	4A maximum (Class 2 Power Limited)
Fuse	7.5A ATM automotive style	
Size	4.00" x 2.50" x 1.75" (102mm x 64mm x 45 mm)	
Weight	0.20lb (0.09kg)	

Regulatory Information


The equipment discussed within this manual has been tested to the following standards:

- UL294, UL603, UL1076
- ULC S318, ULC S319, ULC S533, ULC 60839-11-1
- CSA C22.2 #205
- CSFM Approved

Mounting the B100 Secondary Power Supply

Mounting of the B100 Board to an enclosure is via the four snap-in standoffs supplied.

1. Locate the appropriate mounting holes in the enclosure and snap the standoffs into the holes.
2. Align the board mounting holes with the standoffs (be sure the PC board is properly oriented) and snap the board onto the standoffs.




For ULC S533 Installations: Typical wiring method shall be in accordance with CSA C22.2, Canadian Electrical Code, Part I, Safety Standard for Electrical Installations, Section 32; and CAN/ULC-S524 Installation of Fire Alarm Systems

Connecting the B100 Secondary Power Supply

⚠ Remove all AC and battery power from the FPO system before adding or replacing a B100 board.

⚠ Observe polarity of the DCIN and BR Connections or damage to the system could occur.




⚠ The DC In, DC Out, and BR terminals run through the board for daisy chaining and each terminal set is interchangeable from a functional standpoint.

Either DC IN may be used, either DC Out may be used or either BR may be used interchangeably.

Use Typical Wiring Material Type: UL/CSA recognized insulated wire
Insulation Rating: 300V or higher, 105C or higher, such as UL AWM Style 1581
The maximum length of output wire on DCOUT is limited to the allowable voltage drop on the wire. As a reference, with AWG14 wire (2.525 Ohm/1000ft), connected to an electric strike rated at 24V/0.25A, minimum allowable voltage at the strike terminals is 21.6V (-10% of nominal), the allowable voltage drop on round trip wire is 3.4V. The maximum length of output wire is calculated to be 2693 feet (one way).

B100 – Secondary Power Supply



Class 2 power limited wiring must be separated from non-power limited wiring by a minimum of 1/4 inch and must use separate knockouts.

The installation and all wiring methods shall be in accordance with ANSI/NFPA70 and all local codes.

For ULC compliance, installation and all wiring methods shall be in accordance with the Canadian Electrical Code, C22.1, Part I, Section 32.

All input wiring to the module shall be located within the same room (3m max.).

Le câblage à puissance limitée de classe 2 doit être séparé du câblage non limité en puissance câblage d'au moins 1/4 de pouce et doit utiliser des débouchures séparées.

L'installation et toutes les méthodes de câblage doivent être conformes aux ANSI / NFPA70 et tous les codes locaux.

Pour la conformité ULC, l'installation et toutes les méthodes de câblage doivent être conformes avec le Code canadien de l'électricité, C22.1, partie I, section 32.

Tout le câblage d'entrée du module doit être situé dans la même pièce (3m max.).

1 DC IN Connectors (J1 & J4)

These fastons are the input to the B100. Either faston may be used as the input. Two connections are provided to allow this voltage to pass through to other accessory boards in the system. This input voltage must always be at least 3 volts above the output voltage setting for the B100 to maintain its output.

2 DC OUT Connectors (J2 & J5)

These fastons are the output of the B100 for connection to other accessories in the system. This output may be considered as an equivalent to the DC1 faston of an FPO power supply.

Either or both DC OUT fastons may be used in the system.

⚠ Ensure there are no other voltage sources connected to the buss before powering the system or damage WILL occur.

3 BR Connectors (J3 & J6)

The DC Common buss in the system. All DC power boards in the system must have their BR fastons wired together for proper operation.

4 DC IN LED (D1) – Green

This LED indicates the availability of voltage on the DC IN Buss. When voltage is available on the buss, the LED is lit. This LED is bi-color and indicates the input voltage as follows:

- **Green** – 12V Input
- **Blue** – 24V Input

⚠ NOTE LED colors are range based. Voltage Less than 13V will show Green. Voltage above 20V will show Blue. Voltage between 13 and 20 may show either voltage or a combination Green & Blue. Always verify voltage with a voltmeter.

5 FAULT LED (D7) – Yellow

This LED lights when the B100 detects a fault condition. This fault condition also transmits to the main power supply.

Fault conditions detected include ruptured output fuse, no output, output overload, or output voltage out of regulation.

6 FlexIO Connectors (JP1 & JP2) These connectors allow the fault status of the B100 to be transmitted to the main power supply and pass the FlexIO buss on to other accessory boards in the system.

7 Output Voltage Selection (JP3 & VR1)

This jumper selects the output voltage for the B100 and the potentiometer sets the output voltage when in the adjustable range. In adjustable range, voltage may be set from 5 to 18VDC.

Possible jumper settings are as follows:

- **12V Out** JP3 Position 1
- **Adjustable Output** JP3 Position 2

⚠ The VR1 potentiometer will have no effect unless the jumper is set for the adjustable range.

Note that the input must be at least 3V above the output voltage setting or the B100 will display a fault condition. It may be helpful to temporarily set the input power supply to 24V (Remove load devices first) before setting the B100 output voltage.

8 DC Output

This is the output terminal strip. This terminal strip is non-removable and accepts wire sizes from AWG12 – AWG22. The terminals are labeled on the PC board by the terminal strip.

⚠ CAUTION When powering magnetic loads such as maglocks, door strikes, solenoids, etc, each of these loads must have a reverse protection diode either built-in or external to the device.

9 Output Fuse (F1)

This fuse protects the DC Output terminals. It does not protect the DC OUT faston.

10 DC OUT LED (D4) – Green

This LED indicates the availability of voltage on the DC IN Buss. When voltage is available on the buss, the LED is lit. This LED is bi-color and indicates the input voltage as follows:

- **Green** – 12V Output
- **Blue** – 24V Output

⚠ NOTE LED colors are range based. Voltage Less than 13V will show Green. Voltage above 20V will show Blue. Voltage between 13 and 20 may show either voltage or a combination Green & Blue. Always verify voltage with a voltmeter.

B100 Current Loading

Power drawn from the B100 subtracts from the power available from the source supplying the B100. The most accurate way to determine the draw from the source is to calculate the actual power draw and factor in the efficiency of the B100.

$$P_i = P_o * 1.15$$

Where:

P_i = Input power of the B100

P_o = Output power draw on the B100

B100 Current Load Examples

Example: 1

An FPO250 set for 24V is powering a B100. The B100 is set for an output of 12V and has a 3A total load connected.

$$P_o = 12V \times 3A = 36W$$

$$P_i = 36W \times 1.15 = 41.4W$$

In this example, the B100 will draw 41.4W from the FPO250

This leaves 208.6W available from the FPO250

Example: 2

What size FPO do I need to create a dual voltage power supply providing 12V@4A and 24V@6A?

$$12V \times 4A \times 1.15 = 55.2 \text{ Watts}$$

$$24V \times 6A = 144 \text{ Watts}$$

$$144W + 55.2W = 199.2W$$

The next greater FPO to 199.2 is 250

Use an FPO250 power supply with the B100 converter

Example: 3

What size FPO do I need to create a dual voltage power supply providing 12V@1A and 24V@3A?

$$12V \times 1A \times 1.15 = 13.8 \text{ Watts}$$

$$24V \times 3A = 72 \text{ Watts}$$


$$13.8W + 72W = 85.8W$$

The next greater FPO to 84 is 150


Use an FPO150 power supply with the B100 converter

B100 Application Examples

Dual Voltage (24V/12V) using one FPO, one B100




Dual Voltage (24V/12V) using one FPO, one B100 with 8 output distribution



B100 Application Examples

Triple Voltage (24V/12V/5V) using two FPO's, one B100 with 8 output distribution



FlexPower System Replacement Parts

Board Kits	Description
FPO250	FPO250 replacement board
FPO150	FPO150 replacement board
FPO75	FPO75 replacement board
B100	DC-DC Converter (12VDC or adjustable 5 to 18VDC) replacement board
D8	Simple distribution replacement board
D8P	Simple distribution (Class 2) replacement board
F8	FAI controlled distribution replacement board
F8P	FAI controlled distribution (Class 2) replacement board
C4	Four zone power control replacement board
C4P	Four zone power control (Class 2) replacement board
C8	Eight zone power control replacement board
C8P	Eight zone power control (Class 2) replacement board
M8	Eight zone managed power control replacement board
M8P	Eight zone managed power control (Class 2) replacement board
NL4	Four Port NetLink network communication board (used in FPO systems)
RB8	8A Relay, 12VDC or 24VDC input range, DP/DT

Hardware	Description
AC Cable	AC Input Cable for FPO Power Supply
Battery Cable	Battery Harness – 24"
Module Cable - 12"	Accessory board cable set – 12"
Module Cable - 18"	Accessory board cable set – 18"
Fuse - 3A	ATM-3A Fuse – Bag of 25
Fuse - 5A	ATM-5A Fuse – Bag of 25
Fuse - 7.5A	ATM-7.5A Fuse – Bag of 25
Fuse - 10A	ATM-10A Fuse – Bag of 25
Fuse - 15A	ATM-15A Fuse – Bag of 25
Fuse - 30A	ATM-30A Fuse – Bag of 25
Standoffs	Nylon Standoffs – Bag of 25
Camlock Set	Key and Lock fits LSP "E" enclosure

LifeSafety Power

10027 S 51st St, Suite 102
 Phoenix, AZ 85044 USA
www.lifesafetypower.com
 Phone (888) 577-2898
info1@lifesafetypower.com

IMPORTANT

All information, including illustrations, is believed to be reliable. Users, however, should independently evaluate the suitability of each product for their particular application. LifeSafety Power makes no warranties as to the accuracy or completeness of the information, and disclaims any liability regarding its use. LifeSafety Power's only obligations are those in the LifeSafety Power Standard Terms and Conditions of Sale for this product, and in no case will LifeSafety Power or its distributors be liable for any incidental, indirect, or consequential damages arising from the sale, resale, use, or misuse of the product. Specifications are subject to change without notice. In addition, LifeSafety Power reserves the right to make changes—without notification to Buyer—to processing or materials that do not affect compliance with any applicable specification.